



Greater Dayton Regional Transit Authority
4 S. Main Street
Dayton, OH 45402

April 10, 2019

To: All Prospective Bidders

Re: GD 19-07
Purchase of Pole Cages
Addendum No. 1

Please be aware of the following information regarding the above mentioned procurement.

Question: The specifications start on page 65 of the bid documents. There are no written specifications shown on page 65. Does GDRTA have a written specification for the cages, detailing the grade of the rebar or the coating. Or are we to assume the rebar is Grade 60 and are plain, unfinished?

Answer: Rebar is grade 60 plain and unfinished.

This Addendum No. 1 shall become a part of the contract document and scope of work and shall be taken into consideration when preparing your bid; you are hereby notified accordingly.

Sincerely,

Joe Swisshelm

Joe Swisshelm, C.P.M.
Senior Purchasing Agent
CC: Daron Brown
Alex Smith